

SEPTIC TANK INSPECTION

For compliance with ISDH Rule 410 IAC 6-8.1 Sec. 37-39

Date of Inspection \_\_\_\_\_

Property Owner/Occupant \_\_\_\_\_

Site Address \_\_\_\_\_

Phone Number \_\_\_\_\_

Directions to Property \_\_\_\_\_

\_\_\_\_\_

Approximate Capacity of Tank below water line \_\_\_\_\_ gallons

Minimum water depth in any compartment 30 inches      yes\_\_\_\_ no\_\_\_\_

Maximum depth of water 6 1/2 feet      yes\_\_\_\_ no\_\_\_\_

Proper Inlet baffle      yes\_\_\_\_ no\_\_\_\_

Proper Outlet baffle with gas deflection baffle      yes\_\_\_\_ no\_\_\_\_

Access manholes at least 8 inches in diameter      yes\_\_\_\_ no\_\_\_\_

Inspection access for inlet and outlet baffles      yes\_\_\_\_ no\_\_\_\_

Construction material      concrete\_\_\_\_ Other\_\_\_\_\_

Tank appears to be level      yes\_\_\_\_ no\_\_\_\_

Coated and protected from corrosion      yes\_\_\_\_ no\_\_\_\_

Overall condition of the tank \_\_\_\_\_

In my best judgment, this septic tank complies with Indiana State Department of Health Rule 410 IAC 6-8.1 Residential Sewage Disposal Systems, Section 37 – 39, Septic Tanks.

Yes\_\_\_\_ No\_\_\_\_

Signature of Installer\_\_\_\_\_